

## **SERVICE ADVISORY**

**0808-2012-1**

**Testing LLC Atlanta, Georgia 770-780-2700**

**Dispenser meter upgrade for ethanol blended gasoline above E-10 and up to E-85 blend ratios.**

**Regional Areas Advised;  
United States.**

**Equipment Effected;  
Gilbarco and Dresser Wayne dispensers.**

**It is strongly suggested from this date forward that meters requiring replacement in Gilbarco and Dresser Wayne dispensers be upgraded using NTEP certified meters capable of measuring and dispensing higher blend ratios of ethanol / gasoline. Ethanol blend fuel ratios are expected to increase as II Tier fuel(s) become available in early 2013.**

**NTEP Certificates of Conformance Database Search contains a list of manufactured new and rebuilt measuring device meters approved for anticipated higher ethanol blend ratios.**

**For an approved NTEP meter search one enters meter manufacture or meter rebuilder name;**

**Gilbarco**

**Dresser Wayne**

**Davis Airtec**